



Information provided to the Good Neighbours Group

13th April 2022 Meeting

Plant Issues:

- Lines 1 & 2 suffered some minor issues with pressure part failures including a tube leak on Christmas day.
- A shutdown occurred on Line 2 to adjust the fuel chute.
- Line 3 was shut down for 12 hours to repair a loose pin under the grate.

Environmental:

- The incident for storm damage to the RDF roof was closed out with the repairs conducted with no odour complaints received.
- There have currently been 7 emission limit value exceedances for CO daily average during Q1 for 2022. Six for Line 2 and one for Line 1.
- 1 x 10 minute average exceedance for CO was reported to SEPA for Line 2.
- 1 x daily average for HCl and 1 x daily average for TOC were reported to SEPA.
- 1 x incident report was raised with SEPA for a minor fire with the SFRS in attendance to assist.
- Full environmental permit conditions were administered from the 1st of January 2022 for Line 3 and regulated by SEPA.
- An advisory letter was issued by SEPA relating to non-compliance with the permit condition for feeding waste during a CEMS failure on Line 3.
- 3 members of the site team are currently undertaking a WAMITAB qualification for the treatment of thermal waste.

Community Benefits:

- Challenge Fund winners
- Dundee and Angus Chamber of Commerce business breakfast
- Site tours –
 - ScrapAntics
 - Panbride primary school
 - Dundee and Angus College
- School talks – Fintry primary school



- Sustainable Dundee Network
- Work placements –
 - Grove Academy
 - Perth High School
 - Harris Academy
 - Carnoustie High School